

BOOSTING SOLAR PV MARKETS:

THE ROLE OF QUALITY INFRASTRUCTURE



SUMMARY FOR POLICY MAKERS

© IRENA 2017

Unless otherwise stated, material in this publication may be freely used, shared, copied, reproduced, printed and/or stored, provided that appropriate acknowledgement is given of IRENA as the source and copyright holder. Material in this publication that is attributed to third parties may be subject to separate terms of use and restrictions, and appropriate permissions from these third parties may need to be secured before any use of such material.

About IRENA

The International Renewable Energy Agency (IRENA) is an intergovernmental organisation that supports countries in their transition to a sustainable energy future, and serves as the principal platform for international co-operation, a centre of excellence, and a repository of policy, technology, resource and financial knowledge on renewable energy. IRENA promotes the widespread adoption and sustainable use of all forms of renewable energy, including bioenergy, geothermal, hydropower, ocean, solar and wind energy, in the pursuit of sustainable development, energy access, energy security and low-carbon economic growth and prosperity.

The information in this summary is analysed more extensively in IRENA's full report on the subject.

ISBN 978-92-9260-034-1 (pdf)

Citation: IRENA (2017), *Boosting Solar PV Markets: The Role of Quality Infrastructure*, International Renewable Energy Agency, Abu Dhabi.

Acknowledgements

IRENA is grateful to the following experts for their inputs to this report: Tim Armsby (Eversheds); Víctor Ballivian (IEC National Committee of Chile); Karan Dangayach (Shashwat Cleantech Pvt. Ltd); Carlos Finat (ACERA); Christian Gertig; Werner Herrmann (TÜV Rheinland); Ho Hiang Kwee (Nanyang Technological University); Christophe Inglin (Energetix Pte Ltd.); Robert Jan van Vugt (Eternal Sun); George Kelly (Sunset Technology); Lee Kraemer (First Solar); Sara Kurtz (US National Renewable Energy Laboratory – NREL); Robert Lopez Puckett (Solaready Inc); Shin Matsumi (Eco Solutions Company of Panasonic Group); Sandy Pulsford; Thomas Reindl (SERIS); Omar Roushdy (ERCC); Deven Sharma (Simpa Networks); Colin Steley (Orix); Gerard van Amerongen (Holland Solar); Wilfried van Sark (University of Utrecht); and Stefan Winter (German Metrology Institute–PTB).

This report also benefited greatly from comments and suggestions by: Joerg Althaus (TÜV Rheinland); Daniel Etschmann (KfW); Cristopher Gross (GIZ); Simon Heisig (PTB); Geoffrey S. Kinsey (US Department of Energy); Gaëtan Masson (Solar United); Jörg Mayer (Bundesverband Solarwirtschaft e.V.–BSW); David Moser (EURAC Research); John Smirnow (Global Solar Council); Caroline Tjengdrawira (Tractebel Engineering S.A.); Ioannis Theologitis (ENTSO-E); Eduard Blesa, Elisa Brutto, David Harris, Jean-Luc Kuttel, Jasper Lemmens and Kamal Soundararajan (DNV GL); Greg Ball and Stefan Mau (former DNV GL). Margie Peters-Fawcett edited the publication.

Dolf Gielen, Roland Roesch, Emanuele Taibi, Simon Benmarrage and Pablo Ralon (IRENA) also gave valuable comments and suggestions.

Contributing authors

Francisco Boshell, Alessandra Salgado (IRENA) and Paul Raats (DNV GL).

For further information or to provide feedback: publications@irena.org

This report is available for download: www.irena.org/Publications

Disclaimer

This publication and the material herein are provided “as is”. All reasonable precautions have been taken by IRENA to verify the reliability of the material in this publication. However, neither IRENA nor any of its officials, agents, data or other third-party content providers provides a warranty of any kind, either expressed or implied, and they accept no responsibility or liability for any consequence of use of the publication or material herein.

The information contained herein does not necessarily represent the views of the Members of IRENA. The mention of specific companies or certain projects or products does not imply that they are endorsed or recommended by IRENA in preference to others of a similar nature that are not mentioned. The designations employed and the presentation of material herein do not imply the expression of any opinion on the part of IRENA concerning the legal status of any region, country, territory, city or area or of its authorities, or concerning the delimitation of frontiers or boundaries.

Photographs from Shutterstock unless otherwise indicated

Summary for Policy Makers

The upsurge of solar photovoltaics

By the end of 2016, the global cumulative installed capacity for photovoltaic (PV) power had reached an estimated 290 gigawatts (GW), indicating nearly 50 times the growth in cumulative installed capacity within a decade (see Figure 1.1). The uptrend of new installed capacity is expected to be maintained in the years to come as new markets expand, such as those of Latin America, the Middle East, North Africa and Southern Asia. Projections for total PV installed capacity by 2030 range between 1760 GW and 2500 GW. This can

be attributed in large part to a continued decrease in the levelised cost of electricity (LCOE) expected for solar PV.

The decrease in PV system LCOE over the past decade has been driven by substantial PV module cost reductions, although projected reductions in the coming decade will be largely driven by a decrease in Balance of System (BoS) costs. IRENA estimates that global average total installed cost of new utility-scale PV systems could fall from approximately USD 1.8/watt (W) in 2015 to USD 0.8/W in 2025, a 57% reduction within a decade. A breakdown of typical costs over time is depicted in Figure 1.2.

Figure 1.1. Evolution of cumulative installed capacity for photovoltaic





Figure 1.2. System investment cost breakdown for utility-scale photovoltaics: Global weighted average



Technical risk mitigation

As PV systems reach competitiveness, future market growth will depend on assuring their performance and durability.

The last 5 years, investments in Solar PV overpassed USD 110 billion annually, as reflected in Figure 1.3. 2016 shows lower investments compared to other years, however it was a record year for annual net additions in solar PV technology, this decrease reflects the effect costs reductions are having in this technology. Between 2016 and 2030, investments in PV in the order of USD 2 trillion would be required to achieve the projected approximation of 1500 GW of additional installed capacity. With PV systems rapidly becoming a very competitive power supply option, with trillions of U.S. dollars at stake, more efforts should be made to ensure that these systems deliver as expected throughout their lifetime. Thus, in order to lay the foundation for sustainable market growth, credibility on the technology must be enhanced, and the risk for investors, policy makers and consumers alike must be reduced.


Past results indicate that along the project lifecycle, PV systems observe a failure rate with a 'bathtub' curve. Failure rates are higher at early stages due to technology infancy failures, as are end-of-life stages due to wear (see Figure 1.4). At the early stages of project development, the high risk of failure is commonly borne by the engineering, procurement and construction (EPC) holder and the project developer. These stakeholders are often liable for only a few years, which leads them to focus on ensuring short-term quality. Technology failures may decrease in midlife, leading to higher revenues for lenders and project owners, although the curve – at the end of the lifecycle – will reveal a growing trend in breakdowns due to wear. These risks are ultimately assumed by public entities or communities.

Quality assurance (QA) is crucial in order to reduce electricity costs, since it contributes to ensuring stability for the investors and other stakeholders and it is an essential instrument to protect and accelerate future investments in PV deployment. QA helps to reduce risk by providing the confidence that a product or service will meet expectations which, in turn,

lowers capital costs, raises performance, increases module lifespans and, finally, lowers LCOE. As shown in Figure 1.4,

QA mechanisms may have a substantial positive impact on changing the failure curve shape.


Figure 1.3. Global trends in solar energy investment



Based on: FS - UNEP Centre and Bloomberg New Energy Finance, 2017

Notes: Investment volume adjusts for re-invested equity. Total values include estimates for undisclosed deals. USD = U.S. dollar.

Figure 1.4. Failure curve of solar photovoltaic system



Based on Solar World, 2016

Note: EPC = engineering, procurement and construction.

Bolstering the investment outlook

The implementation of a comprehensive QA framework requires a physical and institutional infrastructure, referred to as quality infrastructure (QI).

QI comprises the entire institutional network and legal framework necessary to regulate, formulate, edit, and implement standards for the common and repeated use of products and services. It also includes the provision of evidence for its fulfilment, including testing, certification, metrology and accreditation.

Within the investment context, QI implementation impacts the key parameters that lie behind the LCOE. Technical risk and the relevant financial rates, the lifetime of the project, and projected energy production are parameters for which QI can significantly reduce uncertainty and enhance performance. A quality-driven environment for emerging technologies and projects can increase investor confidence, enable lower weighted average costs of capital and attract more investments for solar PV technologies.

The importance of quality infrastructure across the value chain

To assure the quality of products will require going beyond the performance role of equipment. It will require the implementation of QI, which will benefit PV systems across the entire value chain.


Quality requires a holistic approach. The implementation of a QA framework covers not only the equipment, but the entire system, including design, installation, operation, maintenance services and disposal. Enacting proper quality schemes, as well as incorporating international practices and stakeholder consultation can impact positively on each of the stages of the technology lifecycle.

A well-developed QI is essential for the sustainable growth of solar PV. At the market level, a national QI that is aligned with international best practices assures quality and safety in the sector. Implementation of QI is effected through the deployment of the elements listed in Figure 1.6.

Figure 1.5. Quality in different aspects of the value chain




Figure 1.6. Elements of quality infrastructure



Implementing QI in the solar PV market benefits the entire value chain and involve all stakeholders, including governments, financiers, project developers, manufacturers, installers and end users.

Figure 1.7. indicates the elements of a QI, such as described above, and the relevant international institutes that relate to each element.

Figure 1.7. Quality infrastructure framework



Based on The National Metrology Institute of Germany (Physikalisch-Technische Bundesanstalt), 2010

Standardisation

There is a core group of international standards, developed by the International Electrotechnical Commission (IEC) and used broadly on a global scale. In addition, there are

country-specific standards that exist, most of which are based on international standards. These measures cover every aspect of the PV value chain, from the system component manufacturing phase through to the end of the technology's life. Specific examples are featured in Figure 1.8.

Figure 1.8. International and country standards applicable to the photovoltaic value chain



International

IEC 62446 – Grid connected photovoltaic systems -- Minimum requirements for system documentation, commissioning tests and inspection

IEC 61724 – Photovoltaic system performance monitoring – Guidelines for measurement, data exchange and analysis

The USA: ASTM E2848 - Standard Test Method for Reporting Photovoltaic Non-Concentrator System Performance

International

IEC 61724 – Photovoltaic system performance monitoring – Guidelines for measurement, data exchange and analysis

IEC 62446-2 – Photovoltaic (PV) – Requirements for testing, documentation and maintenance

The USA: Standard Test Method for Reporting Photovoltaic Non-Concentrator System Performance

International

Decommissioning and waste management options need yet to be properly addressed in international standards.

Directives: like the European Waste Electrical and Electronic Equipment (WEEE) directive, are implemented awaiting transposition into national laws and standards.

Notes: IEC = International Electrotechnical Commission; PV = photovoltaic; NEC = National Electrical Code; AS/NZS = Australian/New Zealand Standard; GB = Chinese Standard.

These are the primary standards most often called upon for project approval or due diligence engineering on behalf of financiers. Further standards that govern manufacturing and testing equipment, sensors, measurements and others provide the QA foundation for product safety and performance. While not specific to PV installations, these standards are relevant and applicable to a variety of other sectors within the electrical industry.

Quality infrastructure development and its different contexts

Successful experience with QI development around the world highlights the benefits of off-grid, distributed generation and utility-scale PV systems.

Table 1.1. lists 11 cases that include developed and developing countries for which the challenges and solutions in developing and implementing QI are indicated. These examples showcase specific measures that relate to the various market development stages. The implementation of QI elements appears highly dependent on country experience and the maturity of the PV market.

Table 1.1. Challenges and solutions for quality infrastructure development

Market	System	Challenges	Solutions
Developing	Utility-scale <i>(e.g. Egypt, Chile)</i>	<ul style="list-style-type: none"> Lack of lender and developer confidence for ambitious governmental programmes due to political instability 	<ul style="list-style-type: none"> Creation of an organisation responsible for regulation, monitoring and quality assurance
	Distributed generation <i>(e.g. China, the Philippines)</i>	<ul style="list-style-type: none"> Lack of quality infrastructure (QI) awareness QI hampered by unattractive incentive scheme Market allows for substandard products 	<ul style="list-style-type: none"> Certification of photovoltaic (PV) installers Guidelines for testing and certification Increasing awareness of QI elements for rooftop PV owners
	Off-grid <i>(e.g. India, Tanzania)</i>	<ul style="list-style-type: none"> Lack of certification process for installers and limited quality assurance for technology, installers and installations 	<ul style="list-style-type: none"> QI improvements in component testing; adoption of international standards; certification and inspection schemes; inclusion of quality criteria in public programmes; and criteria for commissioning and accreditation of public laboratories
Developed	Utility-scale <i>(e.g. U.S., Germany)</i>	<ul style="list-style-type: none"> Transmission and distribution capacities require adjustments in line with increasing PV capacity to meet state utility requirements 	<ul style="list-style-type: none"> Adoption of International Electrotechnical Commission standards in national regulatory frameworks
	Distributed generation <i>(e.g. Singapore, The Netherlands)</i>	<ul style="list-style-type: none"> Unstructured market surveillance Lack of national measurement institutes Private owners are unaware of PV system quality Installations require high-quality assurance 	<ul style="list-style-type: none"> Arrangement for mandatory registration of PV installations Establishment of national solar testing facilities Provision of information about PV system quality to end users Adequate skill requirements for installers
	Off-grid <i>(e.g. Australia)</i>	<ul style="list-style-type: none"> Reducing investor uncertainty through regulatory framework that incorporates quality assurance Installers not appropriately trained for utility-scale projects Clean Energy Collective solar component approval process not adequately thorough 	<ul style="list-style-type: none"> Improved solar component compliance procedure and establishment of a solar retailer code of conduct

The significant effects of quality

The benefits of QI services outweigh their costs. Implementing QI for PV systems may result in significant additional revenue for project owners.

QI implementation and execution measures have an associated cost and require effort. The rationale for implementing a QI, however, is to achieve a positive economic balance by increasing revenues for various actors across the value chain, improving consumer protection, and reducing the carbon footprint.

In the long term, the mitigated costs will outweigh those that relate to the development and implementation of QI. Currently, the costs of reduced quality are partly absorbed by warranty claims and liquidated damages, and these are insufficient to cover all costs of associated quality issues.

Table 1.2. provides an overview of five examples of QI services, as well as the associated costs and expected benefits. These examples were selected based on their capacity to allow for cost benefit analyses.

Table 1.2. Cost/benefit analyses of implementing specific quality infrastructure services

Quality infrastructure service	Cost	Benefit
Development: Solar resource and yield uncertainty		
Energy Production Assessment (EPA) based on measured irradiance data	Measuring local irradiance for at least one year	Reduction of uncertainty in EPA from 8% to 6% leads to an increase in P90 values by 3%. Rewarded through improved loan conditions.
Preconstruction: Prevention of low plant yields		
Batch acceptance testing for wholesale and utility projects	The cost of a batch acceptance test (Typically USD 50 000–55 350 for a 20 megawatt (MW) plant)	A reduction of the degradation rate from 0.75% a year to 0.4–0.6% a year in a project's financial model (Resulting in USD 450 000–1 000 000 of increased revenue over 25 years for a 20 MW plant)
Construction: Performance testing		
Includes independent testing in engineering, procurement and construction contracts on photovoltaic systems performance	The cost of batch testing for a 20 MW plant is USD 276.75–553.50/MW	Photovoltaic module manufacturers deliver modules exceeding contracted performance by 2–3% when batch testing is announced. (Earning an additional EUR 4 000–6 000/MW a year increased generation for a 20 MW plant) (USD 4 428–6 642/MW/year)
Operation and maintenance		
Potential induced degradation (PID) reduction. Inspections to detect, classify and mitigate PID effects	Cost of inspection and corrective actions (for a 6 MW plant in Western Europe: EUR 2 500–4 000/MW) (USD 2 767.5–4 428/MW)	Tackling PID reduces underperformance of 3–5%; however, recovery is not immediate (for the 6 MW plant, EUR 6 000–10 000/MW/year) (USD 6 642–11 070 MW/year)

Quality now and in the near future: Action required

QA is essential to establish the necessary credibility among stakeholders and to enable market growth.

Policy makers can use a staged approach to understand and initiate appropriate measures in developing QI for PV systems. They should bear in mind that quality requirements must be implemented in conjunction with market growth.

QI also acts as a tool to support policies and regulations along the value chain, since it refers to a system that provides the means to appraise conformity with appropriate standards and compliance with relevant regulations. A well-tuned incremental approach can help raise the bar for quality requirements as country capacities and PV markets grow. Well-designed QI requirements are balanced in a way that they do not allow for the deployment of subpar systems; neither are they so stringent that local suppliers and institutions are

unnecessarily restricted. Incentives and specific programmes are deployed in most countries to support PV development in line with market growth.

Nevertheless, photovoltaic equipment and applications may sometimes appear to lag in terms of QA schemes that encourage a sustainable and accelerated deployment of this type of technology. Further research on this topic highlights the fact that the cost of implementing testing and certification requirements, the prevailing absence of capacity issues, and the lack of awareness of QI benefits could contribute to the primary challenges of establishing quality schemes.

In order to maintain the balance between market needs, building affordability and QI implementation for solar PV, the approach should be incremental and linked to the level of PV market maturity. Measures at each stage of market development should be sufficiently flexible to allow for various country considerations. The steps proposed in this report will contribute to the effective development of a PV market through QI measures that are successively implemented.


Figure 1.9. Steps in quality infrastructure development linked to market maturity indication



Making the work of policy makers and regulators easier with quality infrastructure


QI is essential to enable the achievement of renewable energy (RE) policy objectives more effectively. It also facilitates the efforts of relevant key decision makers.

Figure 1.10. Contributing to policy objectives through the implementation of quality infrastructure



Policy makers require instruments that help them reconcile two key macro objectives in the energy sector: i) providing citizens with affordable and reliable energy supply; and ii) fostering sustainable economic growth through deployment of clean and modern technology. QI bridges these two objectives, ensuring that suitable energy technologies promoted by governments deliver as required to effectively fuel economic growth and well-being. However, the importance placed by policy makers on ensuring the quality of renewable energy systems deployed in the country seems to be small in comparison to other factors, such as technology affordability. It is worth noting that focusing on QI may also lead to lower life-cycle costs.

Figure 1.11. Different levels of public policy



The work of policy makers can be eased by using standards, testing and certification in conjunction with policies and regulations. This report illustrates how policy makers can benefit from QI requirements through voluntary and legislative actions including guidebooks, laws, technical regulations, decrees and other actions outlined by a statutory body.



PV markets that achieve a level of maturity reflect lower equipment costs, with quality assurance playing a key role in the mitigation of technology risk and improving equipment performance. Thus, putting QI in place encourages further deployment of solar technologies.



 **IRENA**
International Renewable Energy Agency

www.irena.org

Copyright © IRENA 2017